

**FW: TOFS Sewage Force Main to Report to Primary Cell #2**

---

**From** Erica Janes <ejanes@mvlwb.com>  
**Date** Tue 29-Oct-2024 11:19 AM  
**To** Meg McCluskie <mmclcluskie@mvlwb.com>

Please post to MV2011L3-0001 – 5 Ops and Nots

“Inspector direction re work on Sewage Disposal Facilities”

---

**From:** Wendy Bidwell <Wendy\_Bidwell@gov.nt.ca>  
**Sent:** Tuesday, October 29, 2024 10:17 AM  
**To:** jfoote@fortsmith.ca; Joshua Gauthier <Joshua\_Gauthier@gov.nt.ca>; Erica Janes <ejanes@mvlwb.com>  
**Subject:** TOFS Sewage Force Main to Report to Primary Cell #2

Hi Jesse,

As for your question about whether the Contractor can direct sewage force main flow directly to the Secondary Cell (Cell 3) while doing tie-in/completion work on primary Cell 1, ECC would prefer the force main flow to still report to primary Cell 2 (if there is adequate capacity). This will promote settlement of any solids and guard against exceeding water licence EQC at SNP 567-2.

If you have any questions regarding the above, please let me know.

Regards,  
Wendy Bidwell