

EMERGENCY WALL CHART

Yellowknife Petro-Pass | 332 Old Airport Road | Yellowknife, NT | ☎ 867-873-4001
Outlet #70034

Police

911

Fire

911

Ambulance

911

First Aid Attendants On-Site

All Employees Trained in First Aid

Municipality

Yellowknife

Environmental Release Reporting 24-Hours

1-867-920-8130

Transportation of Dangerous Goods Spill Reporting

1-867-920-8130

Spill Response Contractor

Pario Engineering and Environmental Sciences

1-888-762-4667

Site Manager

Laurence Hamilton – 1-867-688-5061

Associate

Danny/Vandy Lipinski 780-452-1104 / 780-818-4311

Petro-Canada

Wholesale Business Manager

Vikram Sierra 780-619-5489

Sales Coordinator

Calvin Grant 1-403-805-4666

Market Manager

Hasien Mechtab 1-403-333-3256

Construction & Maintenance Advisor

David Wilson 1-403-703-6487

Environmental, Safety & Social Responsibility Advisor

Karl Fandrich 1-403-463-7693

Food Service Advisor

NA

Petro-Canada Communications

1-403-296-4000

Petro-Canada Emergency

1-403-296-3000 – Collect

EMERGENCY PROCEDURES

Fire

1. Immediately shut off power to affected areas, loading and offloading areas. Shut down pumps.
2. Call Fire Department (911).
3. If possible, and safe to do so, attempt to extinguish the fire.
4. Secure area.
5. Evacuate the site, if needed.
6. Call PC Maintenance Control Centre 1-866-494-5050

Spill/Release

1. Immediately shut off power to affected area.
2. Remove all sources of ignition
3. Assess the situation to ensure the safety of those on site, evacuate people as deemed necessary.
4. Call Fire Department (911).
5. Contain spilled by blocking drains and surrounding the product with sorbent.
6. Contact your emergency/spill response contractor as needed or PC Maintenance Contact Centre 1-866-5050 (pumping category).

Injury

1. Ensure no danger to yourself.
2. Secure the scene.
3. Attend to injured person.
4. Notify Ambulance/Fire/Police (911) (as applicable)

Vehicle Accident

1. Shut off power to affected area, as applicable.
2. Call Police (911).
3. Record 3rd parties name, address, phone number, driver's license, and the vehicles license plate number, make, colour and year.
4. Record names, addresses and telephone numbers of any witnesses

Note: Refer to Safety Data Sheet (SDS) for product handling information

Complete Incident Report for all incidents and near misses

Date of Last Review: 2023.02.06

Post by All Telephones

Personal phone numbers of Petro-Canada employees should not be posted.



ENTERPRISE PETRO-PASS

EMERGENCY RESPONSE PLAN

Matonabee Petroleum Ltd.

2 Bear Road

Enterprise, NT

☎ 867-873-4001

May 2022

EMERGENCY RESPONSE PLAN

Table of Contents

- 1.0 Administration
 - 1.1 Revision Status
 - 1.2 How to Use This Generic Emergency Response Plan (ERP)
- 2.0 Introduction
 - 2.1 General Information
 - 2.2 Common Elements of Emergency Response
 - 2.3 Emergency Response Priorities
 - 2.4 Hazard Recognition and Assessment
 - 2.5 Evacuation/Muster Point
- 3.0 Communication/Notification
- 4.0 Emergency Response Guidelines
 - 4.1 Injury
 - 4.2 Spill or Release
 - 4.3 Fire
 - 4.4 Vehicle Accident On-Site
 - 4.5 Bomb Threat or Suspicious Package
 - 4.6 Active Shooter or Physical Violence
 - 4.7 Flooding
 - 4.8 Earthquakes
 - 4.9 Bloodborne Pathogens
- 5.0 Emergency Contacts
 - 5.1 Regulatory Reporting Guidelines
- 6.0 Emergency Wall Chart
 - 6.1 Emergency Wall Chart Use
 - 6.2 Emergency Wall Chart
 - 6.3 Additional Resources
- 7.0 Site Information
 - 7.1 Site Plot Plan Contents
 - 7.2 Site Plot Plan
 - 7.3 Spill Response Equipment
- 8.0 Safety Data Sheets (SDSs)
- 9.0 Acknowledgement
 - 9.1 Associate Acknowledgement
 - 9.2 Employee Review
- 10.0 Appendix
 - Diesel Safety Data Sheet (SDS)

EMERGENCY RESPONSE PLAN

1.0 Administration

1.1 Revision Status

All documents have been revised as of May 2022.

1.2 How to Use This Generic Emergency Response Plan (ERP)

The Emergency Response Plan (ERP) is written for the use of Bulk Plant (Wholesale), Petro-Pass, Cardlock's, and Retail sites.

EMERGENCY RESPONSE PLAN

2.0 Introduction

2.1 General Information

- This ERP contains generic response information for typical on-site emergencies.
- An emergency, for the purposes of this document, is defined as any potential or real situation that may result in serious injury, loss of life, property damage, such as fire, explosion, or damage to the equipment and/or potential impact on the environment, such as a fuel spill.
- Section 4 of the National Fire Code states that any facility involved in the storage, handling, or use of flammable and combustible liquids must have an Emergency Response Plan (ERP) on site.
- The National Fire Code also states that fire drills must be conducted, and the Plan must be reviewed at intervals no greater than 12-months.
- The Associate/Agent/Marketer is responsible to ensure their own plan complies with municipal, provincial, and federal regulations.
- All personnel directly involved with the operation of the site should be familiar with the site's ERP. The Associate should provide training in appropriate emergency response procedures and conduct drills at least once a year to test the adequacy of the ERP and to ensure that their workers are familiar with their roles and responsibilities. It is recommended that all Site staff receive annual fire extinguisher and spill response training.

2.2 Common Elements of Emergency Response

- Regardless of the nature of an emergency at a site, whether it is a fire or vehicle accident, there are requirements and actions which are common to any type of emergency situation at any location.
- To ensure the implementation of safe and effective emergency response actions, personnel at the site should incorporate the following information.

2.3 Emergency Response Priorities

Priorities in an emergency response situation are (in this owner):

- 1) **PEOPLE** – The safeguarding of people and human health;
- 2) **ENVIRONMENT** – The protection of the environment and ecosystems;
- 3) **PROPERTY** – The protection of physical assets;
- 4) **REPORT AND DOCUMENT** – Inform all needed as per communications guidelines in Section 3.1 of this document, complete and submit necessary reports to Petro-Canada and government agencies, keep necessary documentation relating to the event, take pictures, etc.

2.4 Hazard Recognition and Assessment

- The normal human response to an emergency is to “jump right into action”. Far too often this can lead to worse situations than the emergency itself. Immediately upon realizing that an incident is of emergency nature, it is important for you to determine the potential hazards BEFORE taking any action.
- Whenever a hazard is recognized, the potential for loss of human life, including your own, must be carefully evaluated as part of the sequence of response actions.

EMERGENCY RESPONSE PLAN

2.5 Evacuation/Muster Point

- A muster point is a pre-designated meeting place where employees are to gather in the event of an emergency when site evacuation is required. In this manner, all site employees can be accounted for.
- The muster point should be located a safe distance and should be known to all employees.
- This muster point must be clearly identified in the Plot Plan in Section 7 of this document.
- A secondary muster point should be added on all site Plot Plans in Section 7 in the event of an emergency that makes the first muster point a dangerous place to gather.

EMERGENCY RESPONSE PLAN

3.0 Communication/Notification

- One of the most important steps in responding to an emergency is effective communication:
 - Get the assistance needed.
 - Ensure all appropriate personnel are notified.
 - Convey specific information relative to the nature of the emergency.
- Observer (site worker)
 - The first person (Observer) to notice or become aware of an emergency needs to immediately act to limit the impact of the situation.
- The Observer Shall:
 - Notify Fire/Police/Ambulance as needed.
 - Contact Associate/Site Manager.
 - If unable to contact the Site Manager, contact Petro-Canada Maintenance Contact Centre at 1-866-5050 24-hours. If the incident is a spill, asset, or equipment damage, indicate the impacted category such as “Pumping”, “Yard and Building”, and escalate to Petro-Canada Business Manager.
 - If unable to contact Petro-Canada Business Manager and/or Network Maintenance Contractor within one hour, escalate to Petro-Canada’s 24-Hour Emergency Number in Calgary, 403-296-3000.
 - Note that spills are to be called under the “Pumping” category when the Petro-Canada Maintenance Contact Centre is called.
- Associate/Site Manager:
 - Needs to ensure all necessary assistance personnel have been contacted:
 - Petro-Canada Business Manager.
 - If unable to contact the Business Manager, the Site Manager must contact Petro-Canada’s 24-Hour Emergency Number in Calgary, 403-296-3000.
 - Responsible for timely notification of government agencies as required.
 - Responsible to confirm the Petro-Canada Maintenance Contact Centre has been called (in case of spill, asset, and/or equipment damage).

EMERGENCY RESPONSE PLAN

4.0 Emergency Response Guidelines

4.1 Injury

There are three types of injuries:

A **First Aid Injury** can be handled on site using the on-site First Aid Kit. Examples of injuries requiring first aid treatment include minor scratches, cuts, and burns. Treatment may include band aids, antiseptics, etc. and should only be administered by people with first aid training. Register the first aid in the First Aid Journal. If first aid is not enough for the extent of the injury, then medical aid may need to be administered, at which time calling 911 would be required.

A **Medical Treatment Injury** requires the management and care of a patient to address an injury or illness that goes above and beyond first aid. A medical treatment case is any injury that involves neither lost workdays nor restricted workdays, but which requires treatment by a physician or other medical professional. Some examples would include stitches, treatment for 2nd or 3rd degree burns, removal of foreign bodies from a wound, and injuries resulting in prescribed medications. Calling 911 is normally required for medical treatment injuries.

A **Critical Injury** refers to a serious injury that places a life in jeopardy, involves a patient that is unconscious, or has experienced a significant loss of blood, an acute fracture or amputation of a leg or arm, burns over a major portion of the body, loss of sight or other significant losses that require immediate medical attention in a hospital or by a qualified medical practitioner.

A critical injury may be fatal if not dealt with urgently. 911 must be called. The patient should be given immediate medical assistance of first aid and taken to the nearest hospital without any delay. Response time is vital in cases of critical injury.

The scene of a critical injury, especially when work related, should be secured for:

- Investigation by appropriate authorities such as police or an Inspector of Ministry of Labour (MOL).
- No admittance to the scene of the accident except for the purpose of life saving efforts or relieving human suffering, ensuring public utility, service, or transportation system, preventing damage to equipment or property.
- None should disturb, destroy, alter, or remove any article from the scene of the accident.

Reports of critical injuries are to be made to the appropriate authorities immediately. An investigation report is to be forwarded to the concerned offices within a prescribed time limit as per existing laws and regulations.

EMERGENCY RESPONSE PLAN

In the event of a critical injury the following items must be checked to ensure they are considered/completed by appropriate responders:

| ✓ | Action | Notes |
|---|--|---|
| | Ensure no danger to you. | |
| | Call 911 | |
| | Assist the injured person. | Do not move a seriously injured person unless necessary to protect him/her from any further danger. |
| | Consider the need to close the site, secure perimeter. | Obtain photos of incident investigation area, asset, injury, or tools, if it's safe to do so. |
| | Do not disturb anything at scene of incident for investigation. | |
| | Call the Associate/Site Manager. | If unable to contact, call 403-296-3000. |
| | The Associate/Site Manager will notify the territorial Occupational Health and Safety authority as required (see Section 5.0 for specific reporting requirements). | |
| | If an injury involves a WHMIS hazardous substance, refer to the appropriate Safety Data Sheet (SDS) for specific first aid information. | |

EMERGENCY RESPONSE PLAN

4.2 Spill or Release

This section is intended to be used for various types of spills, including but not limited to:

- General product spills
- Product going off-site
- Spills at loading/unloading racks
- Above ground storage tank spills

Staff on site should take the following actions in the event of a spill:

| ✓ | Action | Notes |
|---|---|--|
| | Stop the product flow. Shut down pumps. | If safe to do so, turn off pumps, close valves, block sewers/drains, close dyke drains, close separators/interceptors. |
| | Eliminate all sources of ignition. | Shut off electrical power to the affected area. |
| | Assess the situation to ensure the safety of those on-site, evacuate people as deemed necessary. | |
| | Call 911 | Provide details of the situation. |
| | Establish a safety zone as needed. Secure the affected area. | Restrict and direct traffic in and out. |
| | Contain and control the spill. | Use spill kit, boom, absorbent, drain cover to surround spilled product and prevent it from going off site. |
| | Call your emergency spill contractor as needed. | If the spill is too large to handle with the available spill control materials. If the spill has or might migrate off-site. If the spill has entered any storm drains or catch basins. |
| | Collaborate with emergency services as they arrive on site. | Let them do their jobs. |
| | Notify your Associate/Site Manager and your Petro-Canada Wholesale Business Manager. | If unable to contact, call 403-296-3000. |
| | Call government authorities: municipal, environmental as per territorial/federal regulations. | |
| | Recover spilled product. | |
| | Dispose of contaminated material and/or product. Follow all territorial regulations. | Do not dispose of in garbage. Store outdoors in closes/covered containers. Arrange with a hazardous waste contractor to dispose of these materials in an appropriate manner. Follow WHMIS/TDG labeling requirements. |
| | Ensure all written reports are filed within the prescribed time limits and in accordance with applicable regulations (see Section 5). | Associate's responsibility: Refer to Regulatory Reporting Guidelines. |

EMERGENCY RESPONSE PLAN

4.3 Fire

The actions to take will depend on the size of the fire or other safety aspects to be assessed. Don't hesitate to call 911 for help as it might rapidly become out of control.

| ✓ | Action | Notes |
|---|---|--|
| | Immediately shut off power to affected areas, loading, or unloading areas. Shut down pumps. | |
| | Call 911 | |
| | Assess the situation: can you handle it yourself with no harm to you or others. | If the answer is "YES", use the fire extinguisher. If safe to do so and you are properly trained, attempt to extinguish the fire. Use an appropriate fire extinguisher. Aim the fire extinguisher at the base of the fire and spray from side to side. |
| | If fire is too big to be handled by you, sound the alarm. | To advise others of the situation. |
| | If necessary, shut down the site. | Pumps, electrical, close valves. |
| | Evacuate the area or the site if necessary. | Have all employees and guests leave the site. Employees and contractors gather at muster point. |
| | Establish a safety zone as needed. Secure the affected area. | Restrict and direct traffic in and out. |
| | Collaborate with emergency services as they arrive on site. | Let them handle the situation. |
| | Notify your Associate and your Petro-Canada Wholesale Business Manager. | If unable to contact, call 403-296-3000 |

EMERGENCY RESPONSE PLAN

4.4 Vehicle Accident On-Site

| ✓ | Action | Notes |
|---|--|--|
| | If the accident involves fuel dispensers, or any loading/unloading equipment, activate the emergency shut down button. | |
| | Ask all guests to leave their vehicle and move away from dispensers. | |
| | Call 911 | |
| | Establish a safety zone as needed. Secure the affected area. | Restrict and direct traffic in and out. |
| | Notify Associate and your Petro-Canada Wholesale Business Manager. | If unable to contact, call 403-296-3000. |
| | Record driver information. | |

If a fire or spill ensues, refer to the appropriate section of this ERP for more detailed information.

EMERGENCY RESPONSE PLAN

4.5 Bomb Threat or Suspicious Package

Handle bomb threats seriously and safely! Bomb threats at retail or wholesale establishments are unusual but can happen. Most bomb threats are just threats aimed at trying to cause fear or a reaction like an evacuation.

| ✓ | Action | Notes |
|---|---|--|
| | BOMB THREAT – Write down as much information from the caller as possible. | Stay calm. |
| | Call 911 for police immediately after the threat call. | |
| | Call appropriate contact (Associate, Wholesale Business Manager). | If unable to contact, call 403-296-3000. |
| | Let police handle any suspicious objects or packages. | |
| | IF YOU FIND A SUSPICIOUS PACKAGE – Do not handle. Quickly move all staff and customers out of the building and away from the package. Secure building or immediate area of package. | Immediately call 911 if you find a suspicious package whether or not it is accompanied by a threat. |
| | Initiate emergency shutdown procedures if required. | Shutdown site if needed or requested by Police. |
| | Precautions: <ul style="list-style-type: none"> • Stay Away • Don't Touch • Let the Experts Handle Any Suspicious or Suspect Parcel | |
| | PACKAGE DETONATION <ul style="list-style-type: none"> • Immediately call 911 • Secure the immediate area • Initiate emergency shutdown procedures • Evacuate everyone from the property • Do not touch or handle any remaining packages | Make calls to appropriate contacts (Associate, Petro-Canada Wholesale Business Manager). If unable to contact, call 403-296-3000. |

EMERGENCY RESPONSE PLAN

4.6 Active Shooter or Physical Violence

| ✓ | Action | Notes |
|---|---|---|
| | Lock Doors – Prevent active shooter from entering C-store. | Be aware of environment and possible routes of entry. |
| | Shut off pumps. | |
| | Call 911 to alert Police of active shooter(s) on location. | |
| | Stay low. Stay out of shooters view to provide protection. | Remember customers are likely to follow the lead of workers and managers. Remain calm and stay low. |
| | Cooperate with Police. When Police arrive, remain calm and follow their instructions. | Provide details to Police: <ul style="list-style-type: none"> • Physical description of shooter(s) • Weapon • Location of victim(s) • Video |
| | Provide incident information to Police. | |
| | Notify Associate and Petro-Canada Wholesale Business Manager | If unable to do so, call 403-296-3000. |

EMERGENCY RESPONSE PLAN**4.7 Flooding***To shut down a facility which may be flooded:*

| ✓ | Action | Notes |
|---|--|---|
| | Take a product inventory reading of all aboveground and underground tanks including water level readings. | |
| | Underground tanks should be kept as full of product as possible. Aboveground tanks should be filled to a level at least 25% above the estimated/predicted floodwater elevation. | It time permits, request an emergency delivery of product if necessary. |
| | Seal fill pipe caps to prevent water from entering underground tanks. Close all valves to aboveground tanks. | DO NOT PLUG OR SEAL TANK VENT LINES. |
| | Ensure that aboveground which could float away are secured or tethered in a manner that would prevent floating away from the property. | |
| | Oil/water separators and product sumps should be skimmed of product using sorbent pads or vacuum trucks as appropriate. Close the oil/water separator drain valve. | Spent absorbent pads should be drummed and every effort must be made to remove any waste from the expected flood zones. If time does not allow for removal, the drums must be secured to prevent them from floating away. |
| | Drums and lubricant cubes should be tied down or otherwise secured to prevent floating. | |
| | Propane facilities – contact your propane supplier for appropriate flood emergency procedures. | |
| | Secure used oil collection cabinets. Every effort must be made to remove all waste oil from the expected flood zone. If waste water from the cabinet drains to a waste oil underground tank, ensure the connection is tight. | |
| | If the facility is to be closed/evacuated, shut down the electrical power to the site at the main breaker. Contact the power service utility company to determine if the power service to the facility is going to be cut off. | |
| | Shut down other utilities to the site, including natural gas and potable water. If | |

EMERGENCY RESPONSE PLAN

| | | |
|--|--|--|
| | water is obtained from a water well, secure the well using a well seal. | |
| | Lock all doors and gates to the facility. | |
| | Post a sign in a prominent location identifying the names and telephone numbers where key company personnel can be contacted during the emergency. | |

To start up a facility which has been flooded:

| ✓ | Action | Notes |
|---|--|---|
| | Re-activate utilities to the site (natural gas, water, electricity) and appliances using qualified utility personnel where required. | |
| | Take product inventory readings and dip for water in all tanks to determine if product has leaked out from the tanks or if water has entered the tanks. | Continue to monitor inventory in case of damages causing further leaks. |
| | Take appropriate measures to test product quality. | |
| | Propane facilities – contact your propane supplier for recommissioning your propane facility. | |
| | Pump out water from sumps and containment pans using a qualified petroleum contractor. | If the water is contaminated with product, follow proper procedures for disposal. |
| | Follow all re-entry procedures and requirements for health and safety as provided by your local government authority (disinfecting, potable water, testing, etc.). | |
| | Test all systems, including leak detection systems, cathodic protection, tank level monitors, etc. | |

EMERGENCY RESPONSE PLAN**4.8 Earthquakes*****Key steps during an earthquake:***

| ✓ | Action | Notes |
|---|---|---|
| | If you are inside, do not leave the building when you feel shaking. This is the time to DROP, COVER, AND HOLD ON unless you are clearly in danger such as inside a warehouse with product stacked on high shelves. | DROP, COVER, AND HOLD ON: Crouch down and cover your head and neck with your hands. Get under a nearby desk or heavy table and hang onto it; if it moves, move with it. Stay there until the shaking has stopped completely. Keep away from windows, file cabinets, and other heavy objects that may fall. |
| | Always anticipate aftershocks. | DROP, COVER, AND HOLD ON during aftershocks as well. |
| | If you're outdoors, stay in the open, away from walls, trees, buildings, and power lines. | Move to an open area of the lot and away from the building, canopy, or ID signs and aboveground fuel tanks. |

Key steps after an earthquake:

| ✓ | Action | Notes |
|---|---|--|
| | After the shaking has completely stopped; assess the situation and check for hazards. | Check for injuries and render first aid as needed (seriously injured persons should not be moved unless doing so is the only way to avoid imminent danger of further injury). |
| | Safely exit the building and go to the muster point. | Continue to assess the situation for hazards during exit, on the way to the muster point, and at the muster point. |
| | Take a roll call at the muster point. | Account for all employees, contractors, customers, and visitors. |
| | Do not re-enter any buildings. | Arrangements must be made with a professional structural engineer to inspect offices and buildings following the disaster in order to determine whether or not it is safe to re-enter or continue to operate within. |
| | Leave switches and valves as they are unless a hazard exists such as a gas leak or fuel leak. | Secure the area and keep everyone away from the hazard. Only attempt to shut off a switch or close a valve if there is an obvious hazard and only if it can be done safely. |

EMERGENCY RESPONSE PLAN

4.9 Bloodborne Pathogens

Follow this procedure if you get a needle stick injury or are splashed with bloody or body fluid at work:

| ✓ | Action | Notes |
|---|---|--|
| | Call for assistance if you need it. | |
| | Allow wound to bleed freely. | If the wound is from a needle stick. |
| | Wash injured area well with soap and running water. | |
| | Clean with an antiseptic such as povidone, betadine, or alcohol swabs if available. | |
| | Wash your eyes, nose, or mouth well with large amounts of running water if exposed. | |
| | Remove contaminated clothing. | |
| | Tell your supervisor immediately. | If supervisor is not available, contact HSE Manager. |
| | Go to emergency room of the closest hospital. | |
| | Tell the triage person that you have a puncture injury or a blood or body fluid splash. | |
| | Do not wait in the waiting room. | Remember, if you need treatment for an HIV infected needle, it must be started within 2 hours for best result. |
| | GET TREATMENT. | <p>Some of the things that should happen after a possible exposure:</p> <ul style="list-style-type: none"> You should have blood taken for testing and baseline information. You may be offered vaccine and/or medication treatment. This will depend on the type of exposure. <p>Matonabee Petroleum will:</p> <ul style="list-style-type: none"> Arrange for initial counselling with the Employee Assistance Program. Report the injury to the appropriate territorial OHS authority. |

EMERGENCY RESPONSE PLAN

5.0 Emergency Contacts

5.1 Regulatory Reporting Guidelines

The table on the following page provides guidance as to who shall report (verbal and/or written) certain events to which regulators.

Petro-Canada must be made aware of all events.

EMERGENCY RESPONSE PLAN

Regulatory Reporting Guidelines

| Outcome (Event Type) | Detail | Who Reports | Report To | Report Type | Report Timing |
|---------------------------|--|-------------|--|-------------------------------------|-----------------------------------|
| Fire | Fires that can't be safely and quickly extinguished by site staff. | Associate | Fire Department | Verbal | Immediate |
| Product Leak/Spill | • Onsite and offsite | Associate | NWT Environmental Protection Service – Spill Line 1-867-920-8130 | Verbal | Immediate |
| | • Bulk Transportation | Transporter | Local Police NWT Spill Line Director General – TDG | Verbal Verbal/Written Written | Immediate Immediate 30-Days |
| Propane Release | Any Amount | Associate | NWT Environmental Protection Service – Spill Line 1-867-920-8130 | Verbal/Written | Immediate |
| Injury | Minor/First Aid | Associate | NA | NA | NA |
| | Major/Critical, Injury, or Fatality | Associate | WSCC 1-800-661-0792 | Verbal/Written | Immediate/3-Days |

Diesel Exhaust Fluid (DEF) Reporting Guidelines

Any DEF spills that meet the following criteria must be reported:

- Any amount that causes or may cause an adverse effect; OR
- Any amount released in or near a water body; OR
- Any amount released near or in a sensitive environment or habitat; OR
- Any amount released that is an imminent threat to human health or safety or to species at risk.
- Any amount that exceeds the threshold listed in the table below.

| DEF Spill Reporting Threshold | Who Reports | Reports To | Report Type | Report Timing |
|-------------------------------|-------------|--|-------------|---------------|
| 100 Litres | Associate | NWT Environmental Protection Services – Spill Line 1-867-920-8130 | Verbal | Immediate |

EMERGENCY RESPONSE PLAN

6.0 Emergency Wall Chart

6.1 Emergency Wall Chart Use

- A key component of this Emergency Response Plan is the Emergency Action Wall Chart.
- The Wall Chart is a summary of the telephone contacts and some emergency guidelines.
- Every telephone at the site should have a Wall Chart posted by it.
- Verification should be done by actually calling the contact person.
- Document each verification on the Wall Chart.

Suncor does not take the lead for the spill response because by the time our contractor shows up on site it may be too late. Our SPs are assisting with investigation cause only.

POST A COPY OF THE FILLED IN EMERGENCY WALL CHART TO THE FRONT OF THE EMERGENCY RESPONSE BINDER.

6.2 Emergency Wall Chart

Copy of Emergency Wall Chart found on the following page.

6.3 Additional Resources

| External Contact | Emergency Phone #s (24-Hours) |
|---------------------------------------|--|
| Spill Response Contractor | Pario Engineering & Environmental Sciences 1-888-762-4667 |
| Spill Equipment Provider | Northern Industrial Supplies 1-867-669-7779 |
| Environmental Consultant | Karl Fandrich 1-403-463-7693 |
| Vacuum Truck | KBL Environmental 1-867-872-5263 |
| Electrician | Precision Electric 1-867-766-3605 |
| Pump Service Contractor | All Peace Petroleum 1-780-539-3533 |
| Safety Supplies | Northern Industrial Supplies 1-867-669-7779 |
| Spill Supplies | Northern Industrial Supplies 1-867-669-7779 |
| Regulatory Reporting Authority | NWT Environmental Protection Services – Spill Line 1-867-920-8130 |

EMERGENCY WALL CHART

Enterprise Petro-Pass | 2 Bear Road | Yellowknife, NT | ☎ 867-668-3876

Outlet #38703

Police

911

Fire

911

Ambulance

911

First Aid Attendants On-Site

Unmanned

Municipality

Enterprise

Environmental Release Reporting 24-Hours

1-867-920-8130

Transportation of Dangerous Goods Spill Reporting

1-867-920-8130

Spill Response Contractor

Pario Engineering & Environmental Sciences

1-888-762-4667

Site Manager

Laurence Hamilton – 1-867-688-5061

Associate

Danny/Vandy Lipinski 780-452-1104 / 780-818-4311

Petro-Canada

Wholesale Business Manager

Vikram Sierra 780-619-5489

Sales Coordinator

Calvin Grant 1-403-805-4666

Market Manager

Hasien Mechtab 1-403-333-3256

Construction & Maintenance Advisor

David Wilson 1-403-703-6487

Environmental, Safety & Social Responsibility Advisor

Karl Fandrich 1-403-463-7693

Food Service Advisor

NA

Petro-Canada Communications

1-403-296-4000

Petro-Canada Emergency

1-403-296-3000 – Collect

EMERGENCY PROCEDURES

Fire

1. Immediately shut off power to affected areas, loading and offloading areas. Shut down pumps.
2. Call Fire Department (911)
3. If possible, and safe to do so, attempt to extinguish the fire.
4. Secure area.
5. Evacuate the site, if needed.
6. Call PC Maintenance Control Centre 1-866-494-5050

Spill/Release

1. Immediately shut off power to affected area.
2. Remove all sources of ignition
3. Assess the situation to ensure the safety of those on site, evacuate people as deemed necessary.
4. Call Fire Department (911).
5. Contain spilled by blocking drains and surrounding the product with sorbent.
6. Contact your emergency/spill response contractor as needed or PC Maintenance Contact Centre 1-866-5050 (pumping category).

Injury

1. Ensure no danger to yourself.
2. Secure the scene.
3. Attend to injured person.
4. Notify Ambulance/Fire/Police (911) (as applicable)

Vehicle Accident

1. Shut off power to affected area, as applicable.
2. Call Police (911).
3. Record 3rd parties name, address, phone number, driver's license, and the vehicles license plate number, make, colour and year.
4. Record names, addresses and telephone numbers of any witnesses

Note: Refer to Safety Data Sheet (SDS) for product handling information

Complete Incident Report for all incidents and near misses

Date of Last Review: 2023.01.01

Post by All Telephones

Personal phone numbers of Petro-Canada employees should not be posted.

EMERGENCY RESPONSE PLAN

7.0 Site Information

7.1 Site Plot Plan Contents

To complete the Emergency Response Plan, the Associate/Site Manager shall obtain a copy of the Site Plot Plan from the Petro-Canada Representative. The plan should include as a minimum:

- Buildings and other structures, etc.;
- Location and content of product storage tanks with each tank's capacity;
- Product loading/unloading areas;
- Dispenser islands;
- Product pumps;
- Catch basins and manholes;
- Location of sewers and storm drains;
- OWS;
- Any receiving body of water that could be significantly impacted by a spill;
- Site entrances and exits;
- Location of all fire extinguishers;
- Location of Emergency Shutdown button(s), all ESDs should be named or numbered;
- Location of emergency spill kit;
- Location of muster point. There should be a secondary muster point in case the first one is in harm's way;
- First aid kits and eye wash.

7.2 Site Plot Plan

Enterprise Petro-Pass on the following page.



Enterprise Petro-Pass
2 Bear Road
Enterprise, NT

Enter/Exit



Surface Outlet



OWS

Dispenser 1
Dispenser 2



Diesel Clear
75,000 Litres



ESD

First Aid Kit
Spill Kit
(Inside Building)



Enter/Exit



MUSTER
POINT

EMERGENCY RESPONSE PLAN

7.3 Spill Response Equipment

The contents of the Emergency Spill Kit can be quickly exhausted when responding to an environmental incident. Preparedness is a critical component of the Emergency Response Plan. Because we store, handle, use, and work near hazardous materials we must:

- Ensure Spill Kits are readily available, and the spill response procedures are prominently posted.
- Ensure all employees are trained on spill response, personal protective equipment, and Spill Kit locations.
- Ensure Spill Kits are routinely inspected and used materials are promptly replenished.
- Keep an inventory sheet at each Spill Kit

| Item | Required Amount |
|-------------------------------|----------------------------|
| Oil Pads (White) | 50 |
| Universal Pads (Grey) | 50 |
| Boom | NA |
| Pillow/Socks | 2 X 4' (3") 2 X 4' (3") |
| Aluminum Shovel (Spark Proof) | 1 |
| Neoprene Drain Cover | 1 |
| Disposal Bags | 2 |
| Traffic Cones | 4 |
| Nitrile Gloves | 1 Pair |
| Goggles | 1 Pair |
| Absorbent | 6 Bags |
| Barricade Tape | 1 Roll |
| Plug N' Dyke | 1 |
| Instruction and Re-Order Form | 1 |

EMERGENCY RESPONSE PLAN

8.0 Safety Data Sheets

Safety Data Sheets (SDSs) for all hazardous material transported or stored on site.

List of Applicable SDSs:

- Diesel

EMERGENCY RESPONSE PLAN

9.0 Acknowledgement Form

9.1 Associate Acknowledgement

- I have reviewed the entire plan and have added the appropriate telephone numbers and other site-specific information.
- I have posted the Emergency Action Wall Chart at the appropriate locations immediately adjacent to telephones.
- I am authorized, or any of my employees are authorized by me, to activate the ERP as required.
- All previous plans have been replaced by this plan.

Outlet #38703

#2 Bear Road | Enterprise, NT

Associate: Danny Lipinski

Signature: Danny Lipinski

9.2 Employee Review

This page should be signed by each employee as confirmation they have read the Emergency Response Plan and understand their responsibilities in the case of an emergency. The ERP should be reviewed and signed once every six months by all employees. Signed confirmation pages should be retained for 2-years.

| Name (Please Print) | Signature | Date |
|---------------------|-----------|------|
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

The HSE Manager should review this ERP every six months to ensure it is up to date and verify that all employees have been trained to respond to various emergencies.

| Name (Please Print) | Signature | Date |
|---------------------|-----------|------|
| | | |
| | | |

SAFETY DATA SHEET

DIESEL FUEL

000003000395



Version 6.3

Revision Date 2022/02/01

Print Date 2022/02/01

SECTION 1. IDENTIFICATION

Product name : DIESEL FUEL

Synonyms : Seasonal Diesel, #2 Diesel, #1 Diesel, #2 Heating Oil, #1 Heating Oil, OSX, D50, Arctic Diesel, Farm Diesel, Marine Diesel, Low Sulphur Diesel, LSD, Ultra Low Sulphur Diesel, ULSD, Mining Diesel, Naval Distillate, Dyed Diesel, Marked Diesel, Coloured Diesel, Furnace special, Biodiesel blend, B1, B2, B5, Renewable Diesel blend (RX where X is 2- 50, X is representative of volume %), Diesel Low Cloud (LC), Marine Gas Oil, Marine Gas Oil Dyed

Product code : 103213, 100679, 100654, 100653, 100105, 100992, 100637, 100634, 100631, 100638, 100641, 100635, 100632, 100684, 100683, 100657, 100656, 100655, 100687, 100686, 100685, 100681, 100661, 100659, 100667, 100666, 100665, 100682, 100671, 100669, 100664, 100662, 100680, 100781, 100964, 103204, 103180, 103179, 103193, 103178, 103136, 103135, 103134, 103133, 103132, 103131, 101799, 102907, 102762, 102763, 102755, 102302, 102744, 101801, 100678, 100677, 101802, 100107, 100668, 100658, 100911, 100663, 100652, 100460, 100065, 101796, 101793, 101795, 101792, 101794, 101791, 100768, 100643, 100642, 100103, 101798, 101800, 101797, 101788, 101789, 101787, 102531, 100734, 100733, 100640, 100997, 100995, 100732, 100731, 100994

Manufacturer or supplier's details : Petro-Canada
P.O. Box 2844, 150 - 6th Avenue South-West
Calgary Alberta T2P 3E3
Canada, Telephone: 1-866-786-2671

Emergency telephone number : CHEMTREC: 1-800-424-9300 (toll free) or +1 703-527-3887;
Suncor Energy: +1 403-296-3000

Recommended use of the chemical and restrictions on use

Recommended use : Diesel fuels are distillate fuels suitable for use in high and medium speed internal combustion engines of the compression ignition type. Mining diesels, marine diesels, MDO and naval distillates may have a higher flash point requirement.

Prepared by : Product Safety

SECTION 2. HAZARDS IDENTIFICATION

Emergency Overview

| | |
|------------|--|
| Appearance | Bright oily liquid. |
| Colour | Clear to yellow (This product may be dyed red for taxation purposes) |

SAFETY DATA SHEET

DIESEL FUEL

000003000395



Version 6.3

Revision Date 2022/02/01

Print Date 2022/02/01

| | |
|-------|--------------------------|
| Odour | Mild petroleum oil like. |
|-------|--------------------------|

GHS Classification

| | |
|---|---------------------------------------|
| Flammable liquids | : Category 3 |
| Acute toxicity (Inhalation) | : Category 4 |
| Skin irritation | : Category 2 |
| Carcinogenicity | : Category 2 |
| Specific target organ toxicity - single exposure | : Category 3 (Central nervous system) |
| Specific target organ toxicity - repeated exposure | : Category 2 (Liver, thymus, Bone) |
| Aspiration hazard | : Category 1 |

GHS label elements

| | | |
|-------------------|---|--|
| Hazard pictograms | : |    |
|-------------------|---|--|

| | |
|-------------|----------|
| Signal word | : Danger |
|-------------|----------|

| | |
|-------------------|---|
| Hazard statements | : Flammable liquid and vapour. May be fatal if swallowed and enters airways. Causes skin irritation. Harmful if inhaled. May cause drowsiness or dizziness. Suspected of causing cancer. May cause damage to organs (Liver, thymus, Bone) through prolonged or repeated exposure. |
|-------------------|---|

| | |
|--------------------------|---|
| Precautionary statements | : Prevention: Obtain special instructions before use. Do not handle until all safety precautions have been read and understood. Keep away from heat, hot surfaces, sparks, open flames and other ignition sources. No smoking. Keep container tightly closed. Ground and bond container and receiving equipment. Use explosion-proof electrical/ ventilating/ lighting equipment. Use non-sparking tools. Take action to prevent static discharges. Do not breathe dust/ fume/ gas/ mist/ vapours/ spray. Wash skin thoroughly after handling. Use only outdoors or in a well-ventilated area. Wear protective gloves/ protective clothing/ eye protection/ face protection. Response: |
|--------------------------|---|

SAFETY DATA SHEET

DIESEL FUEL

000003000395



Version 6.3

Revision Date 2022/02/01

Print Date 2022/02/01

IF SWALLOWED: Immediately call a POISON CENTER/doctor.
IF ON SKIN (or hair): Take off immediately all contaminated clothing. Rinse skin with water.
IF INHALED: Remove person to fresh air and keep comfortable for breathing. Call a POISON CENTER/doctor if you feel unwell.
IF exposed or concerned: Get medical advice/ attention.
Do NOT induce vomiting.
If skin irritation occurs: Get medical advice/ attention.
Take off contaminated clothing and wash it before reuse.
In case of fire: Use dry sand, dry chemical or alcohol-resistant foam to extinguish.

Storage:

Store in a well-ventilated place. Keep container tightly closed.
Store in a well-ventilated place. Keep cool.
Store locked up.

Disposal:

Dispose of contents/ container to an approved waste disposal plant.

Potential Health Effects

Primary Routes of Entry : Eye contact
Ingestion
Inhalation
Skin contact

Aggravated Medical Condition : None known.

Other hazards

None known.

SECTION 3. COMPOSITION/INFORMATION ON INGREDIENTS

Substance / Mixture : Mixture

Hazardous components

| Chemical name | CAS-No. | Concentration |
|---|-------------|---------------|
| Kerosine (petroleum), hydrodesulfurized; Kerosine — unspecified | 64742-81-0 | 48 - 100 % |
| Kerosine (petroleum); Straight run kerosine | 8008-20-6 | |
| Fuels, diesel; Gasoil — unspecified | 68334-30-5 | |
| Alkanes, C10-20-branched and linear | 928771-01-1 | 0 - 50 % |
| Fatty acids, C16-18 and C18-unsatd., Me esters | 67762-38-3 | 0 - 20 % |

All above concentrations are in percent by weight.

SECTION 4. FIRST AID MEASURES

If inhaled : Move to fresh air.
Artificial respiration and/or oxygen may be necessary.
Seek medical advice.

In case of skin contact : In case of contact, immediately flush skin with plenty of water for at least 15 minutes while removing contaminated clothing

SAFETY DATA SHEET

DIESEL FUEL

000003000395



Version 6.3

Revision Date 2022/02/01

Print Date 2022/02/01

| | |
|---|---|
| | and shoes. Wash skin thoroughly with soap and water or use recognized skin cleanser. Wash clothing before reuse. Seek medical advice. |
| In case of eye contact | : Remove contact lenses. Rinse immediately with plenty of water, also under the eyelids, for at least 15 minutes. Obtain medical attention. |
| If swallowed | : Rinse mouth with water. DO NOT induce vomiting unless directed to do so by a physician or poison control center. Never give anything by mouth to an unconscious person. Seek medical advice. |
| Most important symptoms and effects, both acute and delayed | : Harmful if inhaled. Respiratory, skin and eye irritation; nausea; cancer. |
| Notes to physician | : Treat symptomatically. For specialist advice physicians should contact the Poisons Information Service. |

SECTION 5. FIREFIGHTING MEASURES

| | |
|---|---|
| Suitable extinguishing media | : Dry chemical Carbon dioxide (CO ₂) Water fog. Foam |
| Unsuitable extinguishing media | : Do NOT use water jet. |
| Specific hazards during fire-fighting | : Cool closed containers exposed to fire with water spray. |
| Hazardous combustion products | : Carbon oxides (CO, CO ₂), nitrogen oxides (NO _x), sulphur oxides (SO _x), smoke and irritating vapours as products of incomplete combustion. |
| Further information | : Prevent fire extinguishing water from contaminating surface water or the ground water system. |
| Special protective equipment for firefighters | : Wear self-contained breathing apparatus for firefighting if necessary. |

SECTION 6. ACCIDENTAL RELEASE MEASURES

| | |
|---|--|
| Personal precautions, protective equipment and emergency procedures | : For personal protection see section 8. Ensure adequate ventilation. Evacuate personnel to safe areas. Material can create slippery conditions. |
| Environmental precautions | : If the product contaminates rivers and lakes or drains inform respective authorities. |
| Methods and materials for containment and cleaning up | : Prevent further leakage or spillage if safe to do so. Remove all sources of ignition. Soak up with inert absorbent material. Non-sparking tools should be used. Ensure adequate ventilation. |

SAFETY DATA SHEET

DIESEL FUEL

000003000395

Version 6.3

Revision Date 2022/02/01

Print Date 2022/02/01



Contact the proper local authorities.

SECTION 7. HANDLING AND STORAGE

- Advice on safe handling : For personal protection see section 8.
Smoking, eating and drinking should be prohibited in the application area.
Use only with adequate ventilation.
In case of insufficient ventilation, wear suitable respiratory equipment.
Avoid spark promoters. Ground/bond container and equipment. These alone may be insufficient to remove static electricity.
Avoid contact with skin, eyes and clothing.
Do not ingest.
Keep away from heat and sources of ignition.
Keep container closed when not in use.
- Conditions for safe storage : Store in original container.
Containers which are opened must be carefully resealed and kept upright to prevent leakage.
Keep in a dry, cool and well-ventilated place.
Keep in properly labelled containers.
To maintain product quality, do not store in heat or direct sunlight.
Ensure the storage containers are grounded/bonded.

SECTION 8. EXPOSURE CONTROLS/PERSONAL PROTECTION

Components with workplace control parameters

| Components | CAS-No. | Value type (Form of exposure) | Control parameters / Permissible concentration | Basis |
|---|------------|----------------------------------|--|-----------|
| Kerosine (petroleum), hydrodesulfurized; Kerosine — unspecified | 64742-81-0 | TWA | 200 mg/m ³ (As total hydrocarbon vapour) | ACGIH |
| | | TWA | 200 mg/m ³ (total hydrocarbon vapor) | CA AB OEL |
| | | TWA | 525 mg/m ³ | CA ON OEL |
| | | TWA | 200 mg/m ³ (As total hydrocarbon vapour) | ACGIH |
| | | TWA | 200 mg/m ³ (total hydrocarbon vapor) | ACGIH |
| Kerosine (petroleum); Straight run kerosine | 8008-20-6 | TWA | 200 mg/m ³ (total hydrocarbon vapor) | CA BC OEL |
| | | TWA | 200 mg/m ³ (total hydrocarbon vapor) | CA AB OEL |
| | | TWA | 200 mg/m ³ (total hydrocarbon | ACGIH |

SAFETY DATA SHEET

DIESEL FUEL

000003000395



Version 6.3

Revision Date 2022/02/01

Print Date 2022/02/01

| | | | | |
|-------------------------------------|------------|-------------------------------------|---|-----------|
| | | | vapor) | |
| Fuels, diesel; Gasoil — unspecified | 68334-30-5 | TWA | 100 mg/m ³ (total hydrocarbons) | CA AB OEL |
| | | TWA (Vapour and inhalable aerosols) | 100 mg/m ³ (total hydrocarbons) | CA BC OEL |
| | | TWA (Inhalable fraction and vapor) | 100 mg/m ³ (total hydrocarbons) | ACGIH |

Engineering measures : Adequate ventilation to ensure that Occupational Exposure Limits are not exceeded.
Use only in well-ventilated areas.
Ensure that eyewash station and safety shower are proximal to the work-station location.

Personal protective equipment

Respiratory protection : Concentration in air determines protection needed.
Use respiratory protection unless adequate local exhaust ventilation is provided or exposure assessment demonstrates that exposures are within recommended exposure guidelines. Respirator selection must be based on known or anticipated exposure levels, the hazards of the product and the safe working limits of the selected respirator.

Filter type : organic vapour cartridge or canister may be permissible under certain circumstances where airborne concentrations are expected to exceed exposure limits. Protection provided by air-purifying respirators is limited. Use a positive-pressure, air-supplied respirator if there is any potential for uncontrolled release, exposure levels are unknown, or any other circumstances where air-purifying respirators may not provide adequate protection.

Hand protection
Material : neoprene, nitrile, polyvinyl alcohol (PVA), Viton(R). Consult your PPE provider for breakthrough times and the specific glove that is best for you based on your use patterns. It should be realized that eventually any material regardless of their imperviousness, will get permeated by chemicals. Therefore, protective gloves should be regularly checked for wear and tear. At the first signs of hardening and cracks, they should be changed.

Remarks : Chemical-resistant, impervious gloves complying with an approved standard should be worn at all times when handling chemical products if a risk assessment indicates this is necessary.

Eye protection : Wear face-shield and protective suit for abnormal processing problems.

Skin and body protection : Choose body protection in relation to its type, to the concentration and amount of dangerous substances, and to the specific work-place.

Protective measures : Wash contaminated clothing before re-use.

Hygiene measures : Remove and wash contaminated clothing and gloves, including the inside, before re-use.

SAFETY DATA SHEET

DIESEL FUEL

000003000395



Version 6.3

Revision Date 2022/02/01

Print Date 2022/02/01

Wash face, hands and any exposed skin thoroughly after handling.

SECTION 9. PHYSICAL AND CHEMICAL PROPERTIES

| | |
|--|---|
| Appearance | : Bright oily liquid. |
| Colour | : Clear to yellow (This product may be dyed red for taxation purposes) |
| Odour | : Mild petroleum oil like. |
| Odour Threshold | : No data available |
| pH | : No data available |
| Melting point | : No data available |
| Boiling point/boiling range | : 150 - 371 °C (302 - 700 °F) |
| Decomposition temperature | No data available |
| Flash point | : > 40 °C (104 °F) Method: closed cup |
| Auto-Ignition Temperature | : 204 °C (399 °F) |
| Evaporation rate | : No data available |
| Flammability | : Flammable in presence of open flames, sparks and heat. Vapours are heavier than air and may travel considerable distance to sources of ignition and flash back. This product can accumulate static charge and ignite. |
| Upper explosion limit | : 6 %(V) |
| Lower explosion limit | : 0.7 %(V) |
| Vapour pressure | : 7.5 mmHg (20 °C / 68 °F) |
| Relative vapour density | : 4.5 |
| Relative density | : 0.8 - 0.88 |
| Solubility(ies) | |
| Water solubility | : insoluble |
| Partition coefficient: n-octanol/water | : No data available |
| Viscosity | |
| Viscosity, kinematic | : 1.3 - 4.1 cSt (40 °C / 104 °F) |

SAFETY DATA SHEET

DIESEL FUEL

000003000395



Version 6.3

Revision Date 2022/02/01

Print Date 2022/02/01

SECTION 10. STABILITY AND REACTIVITY

| | |
|------------------------------------|---|
| Reactivity | : Stable at normal ambient temperature and pressure. |
| Chemical stability | : Stable under normal conditions. |
| Possibility of hazardous reactions | : Hazardous polymerisation does not occur. |
| Conditions to avoid | : Extremes of temperature and direct sunlight. |
| Incompatible materials | : Reactive with oxidising agents and acids. |
| Hazardous decomposition products | : May release COx, NOx, SOx, smoke and irritating vapours when heated to decomposition. |

SECTION 11. TOXICOLOGICAL INFORMATION

Information on likely routes of exposure

Eye contact
Ingestion
Inhalation
Skin contact

Acute toxicity

Product:

| | |
|---------------------------|---|
| Acute oral toxicity | : Remarks: Based on available data, the classification criteria are not met. |
| Acute inhalation toxicity | : Acute toxicity estimate: 1.5 mg/l Exposure time: 4 h Test atmosphere: dust/mist Method: Calculation method Assessment: The component/mixture is moderately toxic after short term inhalation. Remarks: Harmful if inhaled. |
| Acute dermal toxicity | : Assessment: The substance or mixture has no acute dermal toxicity |

Components:

Kerosine (petroleum), hydrodesulfurized; Kerosine — unspecified:

| | |
|---------------------------|--|
| Acute oral toxicity | : LD50 (Rat): > 5,000 mg/kg, |
| Acute inhalation toxicity | : LC50 (Rat): > 5.2 mg/l Exposure time: 4 hrs Test atmosphere: dust/mist |
| Acute dermal toxicity | : LD50 (Rabbit): > 2,000 mg/kg, |

Kerosine (petroleum); Straight run kerosine:

| | |
|---------------------------|--|
| Acute oral toxicity | : LD50 (Rat): > 5,000 mg/kg, |
| Acute inhalation toxicity | : LC50 (Rat): > 5 mg/l Exposure time: 4 h Test atmosphere: dust/mist |
| Acute dermal toxicity | : LD50 (Rabbit): > 2,000 mg/kg, |

SAFETY DATA SHEET

DIESEL FUEL

000003000395



Version 6.3

Revision Date 2022/02/01

Print Date 2022/02/01

Fuels, diesel; Gasoil — unspecified:

Acute oral toxicity : LD50 (Rat): 7,500 mg/kg,
Acute inhalation toxicity : LC50 (Rat): 4.1 mg/l
Exposure time: 4 h
Test atmosphere: vapour
Acute dermal toxicity : LD50 (Mouse): 24,500 mg/kg,

Skin corrosion/irritation

Product:

Remarks: Causes skin irritation.

Serious eye damage/eye irritation

Product:

Remarks: Based on available data, the classification criteria are not met.

Respiratory or skin sensitisation

Product:

Remarks: Based on available data, the classification criteria are not met.

Germ cell mutagenicity

Product:

| | |
|---------------------------------------|---|
| Germ cell mutagenicity- Assessment | Based on available data, the classification criteria are not met. |
|---------------------------------------|---|

Carcinogenicity

Product:

| | |
|-----------------------------------|------------------------------|
| Carcinogenicity - As- sessment | Suspected of causing cancer. |
|-----------------------------------|------------------------------|

Reproductive toxicity

Product:

| | |
|---------------------------------------|---|
| Reproductive toxicity - Assessment | Based on available data, the classification criteria are not met. |
|---------------------------------------|---|

STOT - single exposure

Product:

Target Organs: Central nervous system
Remarks: May cause drowsiness or dizziness.

SAFETY DATA SHEET

DIESEL FUEL

000003000395



Version 6.3

Revision Date 2022/02/01

Print Date 2022/02/01

STOT - repeated exposure

Product:

Target Organs: Liver, thymus, Bone

Remarks: May cause damage to organs through prolonged or repeated exposure.

No data available

Aspiration toxicity

Product:

May be fatal if swallowed and enters airways.

SECTION 12. ECOLOGICAL INFORMATION

Ecotoxicity

Product:

Toxicity to fish :
Remarks: No data available

Toxicity to daphnia and other :
aquatic invertebrates Remarks: No data available

Toxicity to algae :
Remarks: No data available

Toxicity to bacteria : Remarks: No data available

Persistence and degradability

Product:

Biodegradability : Remarks: No data available

Bioaccumulative potential

No data available

Mobility in soil

No data available

Other adverse effects

No data available

SECTION 13. DISPOSAL CONSIDERATIONS

Disposal methods

Waste from residues : The product should not be allowed to enter drains, water courses or the soil.
Offer surplus and non-recyclable solutions to a licensed disposal company.
Waste must be classified and labelled prior to recycling or disposal.
Send to a licensed waste management company.

SAFETY DATA SHEET

DIESEL FUEL

000003000395



Version 6.3

Revision Date 2022/02/01

Print Date 2022/02/01

Dispose of as hazardous waste in compliance with local and national regulations.
Dispose of product residue in accordance with the instructions of the person responsible for waste disposal.
Contaminated packaging : Contact local or business unit authorities for guidance on disposal of product.

SECTION 14. TRANSPORT INFORMATION

International Regulations

IATA-DGR

UN/ID No. : UN 1202
Proper shipping name : Diesel fuel
Class : 3
Packing group : III
Labels : Class 3 - Flammable Liquid
Packing instruction (cargo aircraft) : 366

IMDG-Code

UN number : UN 1202
Proper shipping name : DIESEL FUEL
Class : 3
Packing group : III
Labels : 3
EmS Code : F-E, S-E
Marine pollutant : yes

Transport in bulk according to Annex II of MARPOL 73/78 and the IBC Code

National Regulations

TDG

UN number : UN 1202
Proper shipping name : DIESEL FUEL
Class : 3
Packing group : III
Labels : 3
ERG Code : 128
Marine pollutant : yes

SECTION 15. REGULATORY INFORMATION

This product has been classified according to the hazard criteria of the Hazardous Products Regulations (HPR) and the SDS contains all of the information required by the HPR.

The components of this product are reported in the following inventories:

DSL On the inventory, or in compliance with the inventory

SAFETY DATA SHEET

DIESEL FUEL

000003000395



Version 6.3

Revision Date 2022/02/01

Print Date 2022/02/01

SECTION 16. OTHER INFORMATION

For Copy of SDS : Internet: www.petro-canada.ca/msds
Canada-wide: telephone: 1-800-668-0220; fax: 1-800-837-1228
For Product Safety Information: 1 905-804-4752

Prepared by : Product Safety

Revision Date : 2022/02/01

The information provided in this Safety Data Sheet is correct to the best of our knowledge, information and belief at the date of its publication. The information given is designed only as a guidance for safe handling, use, processing, storage, transportation, disposal and release and is not to be considered a warranty or quality specification. The information relates only to the specific material designated and may not be valid for such material used in combination with any other materials or in any process, unless specified in the text.